



# Recall Alert



## U.S. Consumer Product Safety Commission

Office of Information and Public Affairs

Washington, DC 20207

August 12, 2008  
Alert #08-598

### Cooper Lighting Recalls Emergency and Exit Lights; Could Fail to Stay Illuminated in an Emergency

The following product safety recall was voluntarily conducted by the firm in cooperation with the CPSC. Consumers should stop using the product immediately unless otherwise instructed.

**Name of Product:** "Sure-Lite" and "AtLite" Exit and Emergency Lights

**Units:** About 9,000

**Distributor:** Cooper Lighting Inc., of Peachtree City, Ga.

**Hazard:** The lights can malfunction and not stay illuminated in the event of a power failure. This could result in a failure to provide adequate lighting to guide building occupants to an exit in an emergency.

**Incidents/Injuries:** None reported.

**Description:** The recalled emergency and exit lights are installed in commercial buildings such as hotels and office buildings. The recall includes the following model numbers, which are written on the inside of the removable front cover.

12UEL1SD24X	CHEL1WHSdTDM	UEL1WHSdV
12UEL1SD24XTDM	UELBKSD	LPX70RBKDHSd
12UEL1SD24XWH	UEL1BKSDHAZTDM	LPX70RBKDHSd2146
6CHEL1SD24	UEL1BKSDTDM	LPX70RWHdHSd
6CHEL1SD24WH	UEL1SD	LPX70RWHdHSd2146
AEL1BKSD	UEL1SDA	LPX70RWHdHSdMRT
AEL1BZSD	UEL1SDAV	LPXH70RBKDHSd
AEL1BZSDTDM	UEL1SDC	LPXH70RBKDHSd284
AEL1SD	UEL1SDHAZ	LPXH70RBKSD
AEL1SDTDM	UEL1SDHAZTDM	LPXH70RWHdHSd
AEL1WHSd	UEL1SDTDM	LPXH70RWHdHSd212
AEL1WHSdTDM	UEL1SDV	LPXH70RWHdHSd214

CHEL1BKSD	UEL1WHSD	LPXH70RWHHDHSD2146
CHEL1SD	UEL1WHSDAV	LPXH70RWHHDHSD284
CHEL1SDTDM	UEL1WHSDHAZ	LPXH70RWHHDHSDMRT2139
CHEL1WHSD	UEL1WHSDTDM	LPXH70RWHSD

The date code is located inside the housing and is formatted as XXXX-DDD-YY. For example, the date code "6746-356-07" means the product was manufactured on the 356th day of 2007. Only products with date codes between the 240th day of 2007 and the 101st day of 2008 are included in the recall.

**Sold to:** Authorized distributors nationwide from September 2007 through June 2008. Distributors resold and installed the lights for between \$200 and \$500.

**Manufactured in:** China

**Remedy:** Cooper Lighting is contacting customers directly and is providing a free replacement product.

**Consumer Contact:** For additional information, contact Cooper Lighting at (800) 954-7228 from 8 a.m. to 5 p.m. ET Monday through Friday, or visit the firm's Web sites at [www.surelites-lighting.com](http://www.surelites-lighting.com) or [www.atlite-lighting.com](http://www.atlite-lighting.com)





---

CPSC is still interested in receiving incident or injury reports that are either directly related to this product recall or involve a different hazard with the same product. Please tell us about it by visiting <https://www.cpsc.gov/cgibin/incident.aspx>

The U.S. Consumer Product Safety Commission is charged with protecting the public from unreasonable risks of serious injury or death from thousands of types of consumer products under the agency's jurisdiction. The CPSC is committed to protecting consumers and families from products that pose a fire, electrical, chemical, or mechanical hazard. The CPSC's work to ensure the safety of consumer products - such as toys, cribs, power tools, cigarette lighters, and household chemicals - contributed significantly to the decline in the rate of deaths and injuries associated with consumer products over the past 30 years.

To report a dangerous product or a product-related injury, call CPSC's Hotline at (800) 638-2772 or CPSC's teletypewriter at (301) 595-7054. To join a CPSC e-mail subscription list, please go to <https://www.cpsc.gov/cpsclist.aspx>. Consumers can obtain recall and general safety information by logging on to CPSC's Web site at [www.cpsc.gov](http://www.cpsc.gov).

